

**Invitation To Bid for Construction Services for the
Old 441 South Culvert Replacement Project
ITB 2022-01
ADDENDUM #1**

FEMA EVENT: 4600DR-GA
FEMA PROJECT #: 186575

The following questions were submitted for the above referenced project. Answers to questions are in red italics.

1. How long can the road be closed for construction?
Answer: City Council has agreed to allow the contractor to close the road for up to 7 consecutive days. City staff will place barricades and signs for the road closure. Each local driveway must be afforded access in one direction at any time.
2. Will alternate materials be allowed?
Answer: The City realizes that there are material shortages and long lead times for some items. The City will consider alternatives. Please bid the contract as identified in the ITB, and add an alternate bid for any substitutions, explaining the benefit to the City of the alternate bid.
3. Are there underground utilities in the project area?
Answer: The City is aware of a natural gas line on the east (downstream culvert end) side of the road, and a 6-inch water line on the same side. Also, there is a 2-inch water line on the west side of the road. There is a sewer line in the vicinity, but not crossing the culvert route. Contractors will be responsible for obtaining utility locates for the project.

This addendum shall be signed and attached to any proposals submitted to the City of Clayton for this project. If this addendum is not returned or not signed, responding individuals, companies or other organizations will still be responsible for the requirements of this addendum and the specifications or changes herein.

Acknowledged:

Signature

Printed Name

Date